

Energy performance certificate (EPC)

Flat 4 Castle Haven Foley Terrace MALVERN WR14 4RQ	Energy rating E	Valid until:	2 November 2035
		Certificate number:	5135-1229-8509-0527-6202

Property type	Top-floor flat
Total floor area	77 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's energy rating is E. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Poor
Roof	Pitched, no insulation	Very poor
Window	Single glazed	Very poor
Main heating	Boiler and radiators, mains gas	Good

Feature	Description	Rating
Main heating control	Programmer, no room thermostat	Very poor
Hot water	From main system	Good
Lighting	Below average lighting efficiency	Poor
Floor	(another dwelling below)	N/A
Air tightness	(not tested)	N/A
Secondary heating	Room heaters, wood logs	N/A

Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO₂. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Biomass secondary heating

Primary energy use

The primary energy use for this property per year is 414 kilowatt hours per square metre (kWh/m²).

► [About primary energy use](#)

Smart meters

This property had **no smart meters** when it was assessed.

Smart meters help you understand your energy use and how you could save money. They may help you access better energy deals.

[Find out how to get a smart meter \(https://www.smartenergygb.org/\)](https://www.smartenergygb.org/)

How this affects your energy bills

An average household would need to spend **£2,071 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £1,215 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2025** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 19,820 kWh per year for heating
- 2,665 kWh per year for hot water

Impact on the environment

This property’s environmental impact rating is E. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

Carbon emissions

An average household produces	6 tonnes of CO2
This property produces	5.3 tonnes of CO2
This property’s potential production	1.9 tonnes of CO2

You could improve this property’s CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

► [Do I need to follow these steps in order?](#)

Step 1: Increase loft insulation to 270 mm

Typical installation cost	£900 - £1,200
---------------------------	---------------

Typical yearly saving	£476
-----------------------	------

Potential rating after completing step 1	54 E
--	------

Step 2: Internal wall insulation

Typical installation cost	£7,500 - £11,000
---------------------------	------------------

Typical yearly saving	£505
-----------------------	------

Potential rating after completing steps 1 and 2	68 D
---	------

Step 3: Draught proofing

Typical installation cost	£150 - £250
---------------------------	-------------

Typical yearly saving	£42
-----------------------	-----

Potential rating after completing steps 1 to 3	69 C
--	------

Step 4: Low energy lighting

Typical installation cost	£210 - £245
---------------------------	-------------

Typical yearly saving	£25
-----------------------	-----

Potential rating after completing steps 1 to 4	70 C
--	------

Step 5: Heating controls (room thermostat and TRVs)

Typical installation cost	£220 - £250
---------------------------	-------------

Typical yearly saving	£113
-----------------------	------

Potential rating after completing steps 1 to 5
--

73 C

Step 6: Double glazed windows

Replace single glazed windows with low-E double glazed windows

Typical installation cost	£4,500 - £6,000
---------------------------	-----------------

Typical yearly saving	£55
-----------------------	-----

Potential rating after completing steps 1 to 6
--

74 C

Advice on making energy saving improvements

[Get detailed recommendations and cost estimates](#)

Help paying for energy saving improvements

You may be eligible for help with the cost of improvements:

- Free energy saving improvements: [Warm Homes Local Grant \(WHLG\)](#)
- Heat pumps and biomass boilers: [Boiler Upgrade Scheme](#)
- Help from your energy supplier: [Energy Company Obligation](#)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Guy Putland
-----------------	-------------

Telephone	0203 397 8220
-----------	---------------

Emailsupport@propcert.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme

Elmhurst Energy Systems Ltd

Assessor's ID

EES/004970

Telephone

01455 883 250

Emailenquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration

No related party

Date of assessment

3 November 2025

Date of certificate

3 November 2025

Type of assessment▶ [RdSAP](#)

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at mhclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number[0885-2888-6432-9829-9565 \(/energy-certificate/0885-2888-6432-9829-9565\)](#)**Expired on**27 July 2021




[Help \(/help\)](#) [Accessibility \(/accessibility-statement\)](#) [Cookies \(/cookies\)](#)

[Give feedback \(https://forms.office.com/e/KX25htGMX5\)](https://forms.office.com/e/KX25htGMX5)

[Service performance \(/service-performance\)](#)

OGI

All content is available under the [Open Government Licence v3.0 \(https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/\)](#), except where otherwise stated



© [Crown copyright \(https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/\)](https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/)