Energy performance certificate (EPC)

Flat 2 27 Lawn Crescent RICHMOND TW9 3NS	Energy rating **C**	Valid until:	**28 June 2033**
		Certificate number:	**0267-1202-0707-1841-3204**

Property type

Ground-floor flat

Total floor area

46 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

This property's current energy rating is C. It has the potential to be C.

See how to improve this property's energy efficiency.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Solid brick, as built, no insulation (assumed)	Very poor
Wall	Cavity wall, as built, insulated (assumed)	Very good
Roof	Pitched, insulated (assumed)	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good

Feature	Description	Rating
Lighting	Low energy lighting in all fixed outlets	Very good
Roof	(another dwelling above)	N/A
Floor	Suspended, no insulation (assumed)	N/A
Floor	Solid, insulated (assumed)	N/A
Secondary heating	None	N/A

Primary energy use

The primary energy use for this property per year is 171 kilowatt hours per square metre (kWh/m2).

▶ About primary energy use

How this affects your energy bills

An average household would need to spend **£787 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £75 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2023** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 2,927 kWh per year for heating
- 1,777 kWh per year for hot water

Impact on the environment

This property's current environmental impact rating is C. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year. CO2 harms the environment.

Carbon emissions

An average household produces

6 tonnes of CO2

This property produces

1.4 tonnes of CO2

This property's potential production

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Changes you could make

▶ Do I need to follow these steps in order?

Step 1: Internal or external wall insulation

Typical installation cost

£4,000 - £14,000

Typical yearly saving

£41

Potential rating after completing step 1

76 C

Step 2: Floor insulation (suspended floor)

Typical installation cost

£800 - £1,200

Typical yearly saving

£35

Potential rating after completing steps 1 and 2

77 C

Help paying for energy improvements

You might be able to get a grant from the Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

More ways to save energy

Find ways to save energy in your home.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name
Peter Hussey

Telephone
07774 729 258

Email
info@swiftaspect.co.uk

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme
Quidos Limited

Assessor's ID
QUID200537

Telephone
01225 667 570

Email
info@quidos.co.uk

About this assessment

Assessor's declaration
No related party

Date of assessment
28 June 2023

Date of certificate
29 June 2023

Type of assessment
▶ RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

Certificate number

8165-6622-5379-0469-7996 (/energy-certificate/8165-6622-5379-0469-7996)

Valid until

10 December 2025

Certificate number

8791-3635-1429-1196-6243 (/energy-certificate/8791-3635-1429-1196-6243)

Valid until

16 December 2024

Certificate number

8242-6529-5979-2316-9992 (/energy-certificate/8242-6529-5979-2316-9992)

Expired on

18 November 2022

Certificate number

8222-6529-5759-1316-9992 (/energy-certificate/8222-6529-5759-1316-9992)

Expired on

18 November 2022

Certificate number

2698-6937-6279-5548-6004 (/energy-certificate/2698-6937-6279-5548-6004)

Expired on

20 November 2018

Certificate number

9651-2849-6191-0628-2735 (/energy-certificate/9651-2849-6191-0628-2735)

Expired on

20 November 2018

Certificate number

8548-6520-5979-2369-9076 (/energy-certificate/8548-6520-5979-2369-9076)

Expired on

30 October 2018

Certificate number

9459-2839-6007-0678-3241 (/energy-certificate/9459-2839-6007-0678-3241)

Expired on

30 October 2018

Certificate number

9251-2839-6705-0578-1925 (/energy-certificate/9251-2839-6705-0578-1925)

Expired on

30 October 2018