Energy performance certificate (EPC)

49 Barton Road Osbaston NUNEATON CV13 0EU	Energy rating **C**	Valid until:	**7 September 2032**
		Certificate number:	**1212-9321-2030-0078-5206**

Property type

Mid-terrace house

Total floor area

79 square metres

Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

Energy efficiency rating for this property

This property's current energy rating is C. It has the potential to be B.

See how to improve this property's energy performance.



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Cavity wall, as built, no insulation (assumed)	Poor
Roof	Pitched, 100 mm loft insulation	Average
Window	Fully double glazed	Average

Feature	Description	Rating
Main heating	Boiler and radiators, mains gas	Good
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Good
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Secondary heating	Room heaters, mains gas	N/A

Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO2. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Solar photovoltaics

Primary energy use

The primary energy use for this property per year is 173 kilowatt hours per square metre (kWh/m2).

▶ What is primary energy use?

Additional information

Additional information about this property:

- PVs or wind turbine present on the property (England, Wales or Scotland)
  The assessment does not include any feed-in tariffs that may be applicable to this property.
- Cavity fill is recommended

Environmental impact of this property

This property's current environmental impact rating is C. It has the potential to be B.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year. CO2 harms the environment.

An average household produces

6 tonnes of CO2

This property produces

2.4 tonnes of CO2

This property's potential production

1.5 tonnes of CO2

You could improve this property's CO2 emissions by making the suggested changes. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

Improve this property's energy rating

Follow these steps to improve the energy rating and score.

▶ Do I need to follow these steps in order?

Step 1: Cavity wall insulation

Typical installation cost

£500 - £1,500

Typical yearly saving

£64

Potential rating after completing step 1

82 | B

Step 2: Floor insulation (solid floor)

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£22

Potential rating after completing steps 1 and 2

83 | B

Step 3: Heating controls (room thermostat)

Typical installation cost

£350 - £450

Typical yearly saving

£29

Potential rating after completing steps 1 to 3

84 | B

Step 4: Solar water heating

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£36

Potential rating after completing steps 1 to 4

86 | B

Paying for energy improvements

You might be able to get a grant from the Boiler Upgrade Scheme (https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

Estimated energy use and potential savings

Based on average energy costs when this EPC was created:

Estimated yearly energy cost for this property

£723

Potential saving if you complete every step in order

£150

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

Heating use in this property

Heating a property usually makes up the majority of energy costs.

Estimated energy used to heat this property

Type of heating	Estimated energy used
Space heating	8911 kWh per year
Water heating	2652 kWh per year

Potential energy savings by installing insulation

Type of insulation	Amount of energy saved

Type of insulation	Amount of energy saved
Loft insulation	428 kWh per year
Cavity wall insulation	1439 kWh per year

Saving energy in this property

Find ways to save energy in your home.

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name
Aidan Laney

Telephone
01158800066

Email
admin@talkgreen.co.uk

Accreditation scheme contact details

Accreditation scheme
Stroma Certification Ltd

Assessor ID
STRO034977

Telephone
0330 124 9660

Email
certification@stroma.com

Assessment details

Assessor’s declaration

No related party

Date of assessment

8 September 2022

Date of certificate

8 September 2022

Type of assessment

▶ RdSAP

Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at dluhc.digital-services@levellingup.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.